



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 East Dania Beach Blvd.

Suite 338

Dania Beach, FL 33004

954.399.8478 PH

954.744.4738 FX

contact@buildingdrops.com

## Product Evaluation Report

of

**JELD-WEN, inc.**  
**Architectural Fiberglass Outswing Transom Window**  
**(HVHZ) (Non-Impact)**

for

**Florida Product Approval**

**Report No. 6358**

**Current Florida Building Code**

<b>Method:</b>	<b>1 – A (Certification)</b>
<b>Category:</b>	<b>Windows</b>
<b>Sub – Category:</b>	<b>Fixed</b>
<b>Product:</b>	<b>Architectural Fiberglass Outswing Transom Window (HVHZ) (Non-Impact)</b>
<b>Material:</b>	<b>Fiberglass</b>
<b>Product Dimensions:</b>	<b>99.37" X 24.38"</b>

**Prepared for:**

**JELD-WEN, inc.**

**3737 Lakeport Blvd.**

**Klamath Falls, OR 97601**

**Prepared by:**

**Hermes F. Norero, P.E.**


Florida Professional Engineer # 73778

Date: 9/24/2019

Contents:

Evaluation Report

Pages 1 – 3



Hermes F. Norero, P.E.

Florida No. 73778



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

Date: 9/24/2019

Report No: 6358

---

**Manufacturer:** JELD-WEN, inc.

**Product Category:** Windows

**Product Sub-Category:** Fixed

**Compliance Method:** State Product Approval Method (1)(a)

**Product Name:** Architectural Fiberglass Outswing Transom Window (HVHZ)(Non-Impact)

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **JELD-WEN, inc.** based on Method 1a of the Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **D015630** signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

## Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and does require an impact resistant covering in Wind Zone 3 or less.
4. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and does require an impact resistant covering in Wind Zone 4.
5. Site conditions that deviate from the details of drawing **D015630** require further engineering analysis by a licensed engineer or registered architect.

Hermes F. Norero, P.E.

Florida No. 73778

Page 2 of 3



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

Date: 9/24/2019

Report No: 6358

---

**Certification Agency:** The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a program audited by and approved by **Window and Door Manufacturers Association** (FBC Organization #: CER1508).

**Performance Standards:** The product described herein has been tested per:

- TAS 202-94

**Referenced Data:**

1. Product Testing performed by **National Certified Testing Laboratories** (FBC Organization # TST9341)

Report #

Report Date:

NCTL-310-19-061

07/19/19

Signed and Sealed by Joe Reed, FL PE # 58920

**Installation:**

Refer to Installation Instructions **D015630** for anchor types, edge distance, embedment, spacing and more details of the installation requirements.

**Design Pressure:**

Refer to Installation Instructions **D015630** for design pressures.

Hermes F. Norero, P.E.

Florida No. 73778

Page 3 of 3