

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514592A

Manufacturer: Lippert Components, Inc.
3501 County Road 6 East
Elkhart, IN 46514

Product Line: Series 1700 PVC Sliding Glass Patio Door 96" X 80" – Non-Impact

Compliance:

The product mentioned above has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03528 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: 2179.02-109-12 signed by Lance Cunningam
Molimo, LLC. York, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±40.10psf
Water penetration resistance 7.52psf
3. Anchor calculations, report number 514592-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ±40.0psf
- Unit size: 96" x 80"
- Units must be glazed per ASTM E1300, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded PVC.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03528, Revision A.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

