

# Engineering Evaluation Report #1800-081723

**Prepared by:**

A. Lynn Miller, P.E.  
1070 Technology Dr.  
N. Venice, FL 34275  
(941) 480-1600  
Registration Number: #29296

**Manufacturer:**

NewSouth Window Solutions  
10741 Crossroads Commerce Blvd.  
Tampa FL, 33610  
(813) 626-6000

**Product Description:**

Model 1845, Vinyl, LM & SM Impact Resistant Double Hung Window – FL32346

**Compliance:**

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**


Approval Document: drawing number DH1845-FPA-LM, signed and sealed by A. Lynn Miller, P.E.

Test Report No.: QAI NOK-0009, QAI Laboratories, Inc, Nokomis, FL  
AAMA/WDMA/CSA 101/I.S.2/A440-2017  
ASTM E1886-13a/19 & E1996-17/20

Anchor and Buck Calculations signed and sealed by A. Lynn Miller, P.E., dated 8/12/22.

**Limitations and Conditions of use:**

- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame and sash material to be extruded vinyl.
- Units must be installed in accordance with Approval Documents.



A. Lynn Miller, P.E.  
P.E. #58705