

# Engineering Evaluation Report #8000-081723-1

**Prepared by:**

A. Lynn Miller, P.E.  
1070 Technology Dr.  
N. Venice, FL 34275  
(941) 480-1600  
Registration Number: #29296

**Manufacturer:**

NewSouth Window Solutions  
10741 Crossroads Commerce Blvd.  
Tampa FL, 33610  
(813) 626-6000

**Product Description:**

Model 8400, Vinyl Non-Impact Double Hung Window – FL32346

**Compliance:**


The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval Document: drawing number DH8400-FPA-01, signed and sealed by A. Lynn Miller, P.E.
2. Test Report No.:
  - a. FTL 21-1081  
Fenestration Testing Laboratory, Venice, FL.  
AAMA/WDMA/CSA 101/I.S.2/A440-2017
3. Anchor Calculations; signed and sealed by A. Lynn Miller, P.E., dated 05/25/2021.

**Limitations and Conditions of use:**

- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is not impact resistant and does require impact protection in wind borne debris regions.
- Frame and panel material to be extruded vinyl.
- Units must be installed in accordance with Approval Document, DH8400-FPA-01.



A. Lynn Miller, P.E.  
P.E. #58705