

Engineering Evaluation Report #8450-081723

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

NewSouth Window Solutions
10741 Crossroads Commerce Blvd.
Tampa FL, 33610
(813) 626-6000

Product Description:

Model 8450, Vinyl, Impact Resistant Double Hung Window – FL32346

Compliance:


The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval Document: drawing number DH8450 – FPA, signed and sealed by A. Lynn Miller, P.E.
2. Test Report No.:
 - a. TEL 02031571
Testing Evaluation Labs
AAMA/WDMA/CSA 101/I.S.2/A440-2017.
 - b. TEL 02031571
Testing Evaluation Labs
ASTM E 1886-05/E 1996-09
3. Anchor Calculations; signed and sealed by A. Lynn Miller, P.E., dated 10/18/202

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame and sash material to be extruded vinyl.
- Units must be installed in accordance with Approval Documents.



A. Lynn Miller, P.E.
P.E. #58705