



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Product Evaluation Report

of

**ArmRLite Door Manufacturing Co., Inc.
Custom Min Aluminum and Glass Overhead Sectional Door
(Non-HVHZ) (Non-Impact)**

for

Florida Product Approval

FL# FL32416

Report No. 8625

Current Florida Building Code

Method:	1 – D (Engineering Evaluation)
Category:	Exterior Doors
Sub – Category:	Sectional Exterior Door Assemblies
Product:	Custom Min Aluminum and Glass Overhead Sectional Door
Material:	Aluminum 6063-T5
Product Dimensions:	See Installation Instructions, ARL002

Prepared for:

**ArmRLite Door Manufacturing Co., Inc.
40 Colonial Dr.
Piscataway, NJ 08854**

Prepared by:


Hermes F. Norero, P.E.

Florida Professional Engineer # 73778

Date: 06/22/2023

Contents:

Evaluation Report Pages 1 – 4



Hermes F. Norero, P.E.
Florida No. 73778

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Manufacturer: ArmRLite Door Manufacturing Co., Inc.

Product Category: Exterior Doors

Product Sub-Category: Sectional Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(d)

Product Name: Custom Min Aluminum and Glass Overhead Sectional Door (Non-HVHZ) (Non-Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **ArmRLite Door Manufacturing Co., Inc.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions on **ARL002**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does** require an impact resistant covering.
4. Site conditions that deviate from the details of **ARL002** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions on **ARL002** for size and design pressure limitations.

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Quality Assurance: The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **National Accreditation & Management Institute, Inc.** (FBC Organization #QUA1789).

Performance Standards: The product described herein has been evaluated per:

- ASTM E330-14

Referenced Data:

1. Product Testing performed by **Architectural Testing Inc.**
(FBC Organization #TST4311)
Report #: ATI 01-34472.01, Report Date: 04/16/99
2. Quality Assurance
National Accreditation & Management Institute, Inc.
(FBC Organization #QUA1789)

Installation Method: Please refer to Installation instructions, **ARL002**, for anchor methods, selection, spacing, edge distances, embedment's and further details of installation.

Design Pressure: Please refer to Installation instructions, **ARL002**, for sizes, configurations, and design pressures.

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. **ArmRLite Door Manufacturing Co., Inc.** has tested their products to the following test standard edition(s):

- 1) ASTM E330-97

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) ASTM E330-14

After review of the above mentioned referenced standards and editions, it has been found that no significant technical changes have been made to the test standards that would affect the results. All referenced standards have been found to be equivalent.