

Engineering Evaluation Report # 780LM-040722

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

PGT Industries
1070 Technology Drive
N Venice, FL 34275

Product Description:

SGD780 Series Impact-resistant Aluminum Sliding Glass Door, (LM & SM); FL Approval #33106

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

This product has been evaluated and is in compliance with the current Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).

Supporting Technical Documentation:

1. Approval document: drawing number SGD780-FPA.1, signed and sealed by A. Lynn Miller, P.E.
2. Test Report Nos. FTL-5254, 5273, 5618, 5619, 8322, 8374, ATI 81241.01-401, QAI 21-1218, QAI 21-1241 & QAI 22-1040

TAS 201-94 Large Missile Impact Test
TAS 202-94 Uniform Static Air Pressure Test
TAS 203-94 Cyclic Pressure Loading Test

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame and panel material to be extruded Aluminum.
- Units must be installed in accordance with approval documents.



A. Lynn Miller, P.E.
P.E. #58705