

Evaluation Report PEL-1112A
October 2, 2023

Product Description: Series 415 PVC Fixed Window, Non-Impact, 48" x 120" max. unit size

Manufacturer: Pella Corporation, 102 Main Street, Pella, IA 50219

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:

- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing PEL-1112A, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports NCTL-210-3976-07/08, by National Certified Testing Laboratories, Orlando, FL, with testing performed with equivalency to: AAMA/WDMA/CSA 101/I.S.2/A440-08/11/17
- 4) Supplemental Calculations to support PEL-1112A, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document PEL-1112A.

Limitations of Use: This product:

- May be used up to the sizes and daylight openings with glazing as indicated in PEL-1112A
- Achieves design pressures as shown in PEL-1112A comparative analysis table
- Is non-impact and requires the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires 3/16 tempered I.G. glass minimum as shown in PEL-1112A
- Requires ATN PVC frames with current listing as AAMA 303 Certified Profile Licensee

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Pella Corporation or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



10/2/2023
Lucas A. Turner, P.E.
FL PE #58201