

Evaluation Report PEL-652A
October 5, 2023

Product Description: Series 545 PVC Awning Window, Non Impact, 48" x 36" unit size X

Manufacturer: Pella Corporation, 102 Main Street, Pella, IA 50219

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, PE, at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing PEL-652A, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports NCTL-210-3662-1, -1A, and -1B, from National Certified Testing Laboratories, Orlando, FL signed and sealed by Gerard J. Ferrara, P.E., with testing performed with equivalency to: TAS-202-94 and AAMA/WDMA/CSA 101/I.S.2/A440-08/11/17
- 4) Supplemental Calculations to support PEL-652A, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to approval document PEL-652A.

Limitations of Use: This product:

- May be used up to sizes of 48" x 36" unit size X, with glass types and max. glass daylight sizes as shown in PEL-652A
- Achieves design pressures as shown in PEL-652A
- Is nonimpact and requires the use of shutters in windborne debris regions
- May be used in the High Velocity Hurricane Zone
- Requires Quanex or Veka white rigid PVC framing per current Miami-Dade NOA. I have evaluated these framing materials and find that they comply with the requirements of the 8th Ed. (2023) Florida Building Code for use in this product.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Pella Corporation or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



10/5/2023
Lucas A. Turner, P.E.
FL PE #58201