

## **AL-FAROOQ CORPORATION**

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

## PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 38057

Date: 03/01/2021

**Detailed Product Description:** 

Manufacturer: MR-GLASS DOORS & WINDOWS MANUFACTURING LLC.

Manufacturer Address: 8051 NW 79th PLACE, MEDLEY, FL 33166

Model Name: MG-1500 ALUMINUM SLIDING GLASS DOOR Maximum Load: +65 PSF, -80 PSF (Large Missile Impact)

**Installation Drawings #** 21-16F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used X Yes \_\_\_ No

## Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Hurricane Engineering & Testing Inc.	02/11/2021	HETI-20-8095	Rafael E. Droz-Seda, PE
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Hurricane Engineering & Testing Inc.	02/11/2021	HETI-20-8095	Rafael E. Droz-Seda, PE
ASTM E330 & TAS 202	Uniform Static Air Press.	Hurricane Engineering & Testing Inc.	02/11/2021	HETI-20-8095	Rafael E. Droz-Seda, PE
ASTM F842	Forced Entry	Hurricane Engineering & Testing Inc.	02/11/2021	HETI-20-8095	Rafael E. Droz-Seda, PE

## Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT	TEST	Test
			DATE	REPORT #	Sealed by
FBC 1626.2 (TAS 201 & 203) ASTME1886/1996	Large Missile Impact & Cyclic	Hurricane Engineering & Testing Inc.	02/11/2021	HETI-20-8095	Rafael E. Droz-Seda, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2020 Florida Building Code.

**Evaluation Report Engineer:** 

No. 81223 No. 81223 STATE OF CORIDA SEALED: 3/18/2021

Jalal Farooq PE # 81223 Al-Faroog Corporation EB # 3538