

Registry No. 29824 17520 Edinburgh Dr Tampa, FL 33647 (813) 480-3421

Issued April 15, 2021

EVALUATION REPORT

FLORIDA BUILDING CODE, 7TH EDITION (2020)

Manufacturer: ATLAS ROOFING CORPORATION

2000 Riveredge Parkway, Suite 800

Atlanta, GA 30328 (770) 612-6267 www.atlasroofing.com

Manufacturing Location: Greencastle, PA

Quality Assurance: UL LLC (QUA9625)

SCOPE

Category:RoofingSubcategory:UnderlaymentsCode Sections:1507.1.1, 1518.4Properties:Physical properties

REFERENCES

 Entity
 Report No.
 Standard
 Year

 Nemo|etc. LLC (TST6049)
 4j-TAR-20-SSUDL-02.A
 ASTM D 1970
 2015a

PRODUCT DESCRIPTION

WeatherMaster® Ice and Water 200 (805D300SEL)

ASTM D 1970 SBS modified, self-adhering, mineral surfaced underlayment

reinforced with a fiberglass mat.

APPLICATION METHOD

Installation shall be in accordance with the published manufacturer's installation instructions, the FBC, and the requirements below.

Deck substrates shall be clean, dry, and free from any irregularities and debris. All fasteners in the deck shall be checked for protrusion and corrected prior to underlayment application.

The roof deck shall be constructed of closely fitted plywood sheathing for new or existing construction. Plywood deck shall be installed in accordance with FBC requirements. Roof decks shall have no more than 1/8" gap at abutting joints.

Exposure of the underlayments shall be limited to a maximum 30 days.

Self-adhering underlayments may be adhered to plywood sheathing, OSB sheathing, ASTM D 226 organic felt, or ASTM D 41 primed structural concrete substrates.

Roof coverings shall be mechanically fastened through the underlayment to the roof deck.

Allowable Roof Coverings:

Underlayment	Asphalt Shingles	Metal Roof Panels and Shingles	Composite or Photovoltaic Shingles	Wood Shingles and Shakes	Slate Shingles	Clay and Concrete Tile
WeatherMaster® Ice and Water 200	Υ	N	Υ	Υ	Y	N

ATL21001 FL38096 Page 1 of 2




LIMITATIONS

- 1) This report is not for use inside the HVHZ.
- 2) Fire Classification is not within the scope of this evaluation.
- 3) Roof slope limitations shall be in accordance with FBC requirements.
- 4) Installation of the evaluated product shall comply with this report, the FBC, and the manufacturer's published application instructions. Where discrepancies exist between these sources, the more restrictive and FBC compliant installation detail shall prevail.
- 5) Products described within this report may be used as described in other current FBC product approval documents.
- 6) Roof coverings shall not be adhered directly to the underlayment unless otherwise approved in this or other current FBC product approval documents.
- 7) All products listed in this report shall be manufactured under a quality assurance program in compliance with Rule 61G20-3.

COMPLIANCE STATEMENT

The products evaluated herein by Zachary R. Priest P.E. have demonstrated compliance with the Florida Building Code, 7th Edition (2020) including High-Velocity Hurricane Zones (HVHZ) as evidenced in the referenced documents submitted by the named manufacturer.



This item has been digitally signed and sealed by Zachary R. Priest, PE, on 4/15/2021.

Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Zachary R. Priest, P.E. Florida Registration No. 74021 Organization No. ANE9641

CERTIFICATION OF INDEPENDENCE

CREEK Technical Services, LLC does not have, nor will it acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

CREEK Technical Services, LLC is not owned, operated, or controlled by any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any company manufacturing or distributing products under this evaluation.

Zachary R. Priest, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.

END OF REPORT

ATL21001 FL38096 Page 2 of 2