

Engineering Evaluation Report #9600-121922.1

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

NewSouth Window Solutions
10741 Crossroads Commerce Blvd.
Tampa FL, 33610
(813) 626-6000

Product Description:

9000 Series, Model 9600, Vinyl Non-Impact Picture Window – FL39123

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

Approval Document: drawing number PW9600-FPA-01, signed and sealed by A. Lynn Miller, P.E.


Test Report No.: ATI C6764.07-501-44; Architectural Testing Laboratory
AAMA/WDMA/CSA 101/I.S.2/A440-2017

Test Report TEL 02031566, Testing Evaluation Lab-signed and sealed by William B. Shelton
TAS 201, 202, 203-94

Anchor, Buck and Comparative Analysis Calculations signed and sealed by A. Lynn Miller, P.E., dated 12/13/2021.

Limitations and Conditions of use:

- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is not impact resistant and does require impact protection in wind borne debris regions.
- Frame and panel material to be extruded vinyl.
- Units must be installed in accordance with Approval Documents.



A. Lynn Miller, P.E.
P.E. # 58705