

# Engineering Evaluation Report

**Prepared by:**

A. Lynn Miller, P.E.  
1070 Technology Dr.  
N. Venice, FL 34275  
(941) 480-1600  
Registration Number: #29296

**Manufacturer:**

Eco Window Systems  
9114 NW 106 St.  
Medley, FL 33178  
(305) 885-5299

**Product Description:**

Series "600", Non-Impact Resistant, Aluminum Outswing Entrance Door, FL# 39630

**Compliance:**

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

This product has been evaluated and is in compliance with the current Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).

**Supporting Technical Documentation:**

1. Approval Document: drawing number "FD600FPA - NI", signed and sealed by A. Lynn Miller, P.E.
2. Test Report No. HETI-20-8063 signed by Rafael E. Droz-Seda, P.E.; Hurricane Engineering & Testing Inc. Test Standards: TAS 202-94 & ASTM E547/E331 Water Penetration & ASTM E283 Air Infiltration Leakage & ASTM F842 Force Entry, dated 01/14/21.
3. Anchor verification calculations and structural analysis, dated 06/02/15.

**Limitations and Conditions of use:**

- Maximum Design Pressure: +61.6.0/-67.7 psf
- Maximum Tip-to-Tip Frame Size: 76" x 98"
- Maximum DLO: 32-3/4" x 87"
- Units must be glazed per ASTM E1300-09, refer to approval document for glazing details.
- This product is not impact resistant and will require impact protection in wind borne debris regions.
- Frame material to be extruded aluminum.
- Units must be installed in accordance with Approval Document.

