L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434 – 688 – 0609 rllomas@lrlomaspe.com

Report No.: 511231M

Manufacturer: Provia, LLC.

2150 State Route 39 West Sugarcreek, OH 44681

Product Line: 20GA Steel IS Patio Door w/ and w/ out Sidelites and Transom

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-00709, Revision M, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test Report No.: NCTL 110-11912-3 signed by Robert H. Zeiders, P.E.

National Certified Testing Laboratories, York, PA.

ASTM E330

Design pressure: +45.0psf/-50.0psf

3. Test Report No.: NCTL 110-11282-1 signed by Robert H. Zeiders, P.E.

National Certified Testing Laboratories, York, PA.

ASTM E330

Design pressure: ±103.3psf Water penetration resistance 0.0psf

4. Test Report No.: NCTL 110-11320-1, single door w/ Trilennium hardware, signed and sealed by Robert H. Zeiders,

P.E. National Certified Testing Laboratories, York, PA.

ASTM E330

Design pressure: ±116.6psf

5. Test Report No.: NCTL 110-13258-1 signed by Robert H. Zeiders, P.E.

National Certified Testing Laboratories, York, PA.

ASTM E330

Design pressure: ±80.0psf

6. Test Report No.: 3172703MID-011, signed by Kent Kelsey

Intertek Testing Services NA Inc., Middleton, WI

NFPA 252 & UL 10C

Steel skin door with polyurethane foam core complies with NFPA 252 and UL 10C Positive Pressure Fire Test of Door Assemblies for a 90 minute rating with hose stream.

7. Test reports: TEL01680148, TEL01680149 and TEL01680150 signed and sealed by Lyndon F. Schmidt P.E.

Testing Evaluation Laboratories, Inc. Plant City, FL.

Fiberglass testing

ASTM D635 Rate of burning classification: CC1
ASTM D1929 Self ignition temperature: 778°F
ASTM D2843 Smoke density rating: 60.4

8. Report No.: L0606.01-501-47-R0 signed by Stephen D. Shank.

National Certified Testing Laboratories, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440

Design pressure: ±50.13psf Water penetration resistance 0.0psf

- Anchor calculations, report number 511231-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 10. Comparative analysis, report number 511679-2, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 11. Evaluation and comparative analysis for alternate sills, report numbers 514581A, prepared, signed and sealed by Luis Roberto Lomas P.E.12. Evaluation and comparative analysis, report number 514394A, prepared, signed
- and sealed by Luis Roberto Lomas P.E.
- 13. Evaluation for additional trims, report number 514783, prepared, signed and sealed by Luis Roberto Lomas P.E.



Luis R. Lomas, P.E. FL No.: 62514 09/08/2021

L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434 – 688 – 0609 rllomas@lrlomaspe.com

Report No.: 511231M

Limitations and Conditions of use:

Design pressure: +45.0psf/-50.0psf

Approved configurations:
 Inswing (X, XO, OX, OXO, O/X, O/XO, O/OX and O/OXO)

Door panel and sidelite sash size: 35 3/4" x 78 15/16"
Transom size: 109 9/16" x 15 1/4"
Frame size: 109 9/16" x 96 ¾"

• Units to be glazed per ASTM E1300 with safety glazing.

This product is not rated to be used in the HVHZ.


- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Door frame material: Wood G.46 minimum or Framesaver or Fusion Frame.
- Door panel and sidelite sash material to be 20Ga. minimum steel with steel or fiberglass top and bottom rails.
- Approved lock hardware:
 - o Schlage F-Series door knob with Schlage B-Series deadbolt.
 - o Emtek Residential Grade door hardware assembly.
 - oTrillenium Multi-Point lock handle assembly.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-00709, Revision M.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 09/08/2021