



# AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

## PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 41587

Date: 06/10/2022

**Detailed Product Description:**

**Manufacturer:** EXCLUSIVE WOOD DOORS

**Manufacturer Address:** 2000 NW 95th AVENUE, DORAL, FL. 33172

**Model Name:** DIRECT SET FIXED WOOD WINDOW

**Maximum Load:** +70 PSF, -70 PSF (Large Missile Impact)

**Installation Drawings #** 22-19F

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.					
Comparative analysis used <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
<b>Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)</b>					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E283	Air Infiltration Leakage	Blackwater Testing, Inc	05/18/2022	BT-EWD-21-002	Michael D Caldwell, PE
ASTM E331 OR ASTM 547 & TAS 202	Water Penetration	Blackwater Testing, Inc	05/18/2022	BT-EWD-21-002	Michael D Caldwell, PE
ASTM E330 & TAS 202	Uniform Static Air Press.	Blackwater Testing, Inc	05/18/2022	BT-EWD-21-002	Michael D Caldwell, PE
ASTM F588	Forced Entry	Blackwater Testing, Inc	05/18/2022	BT-EWD-21-002	Michael D Caldwell, PE
<b>Supplemental Tests (Tested in accordance with TAS-201 and TAS-203)</b>					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
FBC 1626.2 TAS 201 & 203 ANSI Z97.1	Large Missile Impact & Cyclic	Blackwater Testing, Inc	05/18/2022	BT-EWD-21-002	Michael D Caldwell, PE
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2020 Florida Building Code.					
<b>Evaluation Report Engineer:</b>			Sealed: 6-15-2022		
Jalal Farooq Al-Farooq Corporation		PE # 81223 EB # 3538			