$\begin{smallmatrix}R&&&&\\&W&&&\\&&B&C\end{smallmatrix}$

R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry
P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197
Florida Board of Professional Engineers Registry License No. 9813

Product Evaluation Report

Report No.:

FL-41788.12

Date:

August 21, 2023

Product Category	Sub Category	Manufacturer	Product Name	
Exterior Doors	Swinging Exterior Door Assemblies	Premier Products, Inc. 3228 6th Avenue North Birmingham, AL 35201 (205) 322-7700	"D" Series Single Opaque Door "Impact" Outswing	

Scope:

Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Premier Products, Inc. based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- 1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- 3. When used in areas requiring wind borne debris protection this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not need to be protected with an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
- 4. The "D" door achieves a Class I stiffness classification per Section 8.2.2 of ANSI A250.13.
- 5. Site conditions that deviate from the details of drawing FL 41788.12 require further engineering analysis by a licensed engineer or registered architect.
- 6. See drawing FL-41788.12 for size and design pressure limitations.

Test Standard

Supporting Documents:

Test Penert No

i. <u>rest kep</u> t	<u> IE</u>	Si Sianuaru	resumy Laboratory	<u>Signed by </u>
CTLA-958	BW TA	AS 201-94, 202-94 & TAS 203-94	Certified Testing Laboratories	Ramesh Patel, P.E.
TEL 06-10)05-1 AS	STM E330-02, E331-00	Testing Evaluation Lab.,Inc.	Wendell W. Haney, P.E.
	AS	STM E1996/1886-02		
2. Drawing I	No. Pr	epared by		Signed & Sealed by
No. FL-41	788.12 RV	W Building Consultants, Inc. (#9813)		Lyndon F. Schmidt, P.E.
3. Calculation	ons Pr	epared by		Signed & Sealed by
Anchoring	R\	W Building Consultants, Inc. (#9813)		Lyndon F. Schmidt, P.E.
7 111011011119	111	building Consultants, inc. (#3013)		Lyndon i . Commut, i .L.

Testing Laboratory

4. Quality Assurance

Certificate of Participation issued by National Accreditation and Management Institute, certifying that Premier Products, Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409 This item has been digitally signed and sealed by L. F. Schmidt on 8-21-23. Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.

Signed by