

L. Roberto Lomas P.E.

400 Palm Ave.
Indialantic, FL 32903
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515075

Manufacturer: E6 Global IPA, LLC.
12-1394, 369 Gangnam-Daero, Seocho-Gu
Seoul 06621, South Korea

Product Line: AZ57-HWF2 Aluminum Bifold Door Non-Impact

Compliance:

The product mentioned above has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03854, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NCTL 210-4242-04 signed and sealed by Douglas J. McDougall P.E.
National Certified Testing Laboratories, Orlando, FL
TAS 202 Uniform Static Air Pressure, ± 60.0 psf design pressure, 9.0psf water penetration.
3. Test report No.: NCTL 210-4242-05 signed and sealed by Douglas J. McDougall P.E.
National Certified Testing Laboratories, Orlando, FL
TAS 202 Uniform Static Air Pressure, ± 60.0 psf design pressure, 9.0psf water penetration.
4. Test report No.: NCTL 210-4242-10 signed and sealed by Douglas J. McDougall P.E.
National Certified Testing Laboratories, Orlando, FL
TAS 202 Uniform Static Air Pressure, ± 60.0 psf design pressure, 9.0psf water penetration.
5. Test report No.: NCTL 210-4242-11 signed and sealed by Douglas J. McDougall P.E.
National Certified Testing Laboratories, Orlando, FL
TAS 202 Uniform Static Air Pressure, ± 60.0 psf design pressure, 9.0psf water penetration.
6. Anchor calculations, report number 514914-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 60.0 psf
- Panel size: 36" x 96"
- Approved configurations: XXXX, XXX, XX
- Units must be glazed per ASTM E1300, with safety glazing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T5.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03854.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

