

L. Roberto Lomas P.E.

400 S Palm Ave
Indialantic, FL 32903
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515089

Manufacturer: **Therma-Tru Corporation**
 1750 Indian Wood Circle
 Maumee, OH 43537

Product Line: Series V-3 Standard In/Out Aluminum FGW Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03866, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NCTL-110-15327-2 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
ASTM E330
Design pressure: ± 70.0 psf
Water penetration resistance 12.0psf
3. Test report No.: NCTL 110-15505-1 signed and sealed by Robert H Zeiders P.E.
National Certified Testing Laboratories, York, PA
TAS 202 Uniform Static Air Pressure, ± 55.0 psf design pressure, 9.0psf water penetration.
4. Anchor calculations with comparative analysis, report number 515089-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: Refer to installation instructions.
- Approved configurations: Unlimited number of panels in unlimited configurations are approved as long as individual panel area does not exceed 33.32 ft² and uses vertical conditions as shown in approval document.
- Units must be glazed per ASTM E1300, see installation instructions for glass options.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded Aluminum 6063-T6

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03866.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

