## L. Roberto Lomas P.E.

# **Engineering Evaluation Report**

400 S Palm Ave Indialantic, FL 32903 434-688-0609 rllomas@lrlomaspe.com

Report No.: 515100

Manufacturer: Therma-Tru Corporation

1750 Indian Wood Circle Maumee, OH 43537

#### **Product Line:**

Series V-3 Thermally-Broken AL French Door Assembly w/Standard & High Performance Thresholds Non-Impact

## Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

## Supporting Technical Documentation:

- 1. Approval document: drawing number 08-03872, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: NCTL 110-19489-1 signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

TAS 202 Uniform Static Air Pressure, ±40.0psf design pressure, 12.11psf water penetration.

3. Report No.: NCTL 110-19489-2 signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440

Design pressure: ±40.0psf Water penetration resistance 12.11psf

4. Anchor calculations, report number 515093-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

### Limitations and Conditions of use:

- Maximum design pressure: Refer to approval drawing
- Maximum unit size: Refer to approval drawing.
- Units must be glazed per ASTM E1300, with safety glazing.
- This product is rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded Aluminum 6063-T5 and 6063-T6.

#### Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03872.

## Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

\* No. 6251# \*

No. 6251# \*

No. 6251# \*

STATE OF WILLIAM

ONAL ENGINEER

NO. 6251#

NO.

Luis R. Lomas, P.E. FL No.: 62514 12/19/2022