L. Roberto Lomas P.E.

Engineering Evaluation Report

400 S Palm Ave Indialantic, FL 32903 434-688-0609 rllomas@lrlomaspe.com

Report No.: 515099

Manufacturer: Therma-Tru Corporation

1750 Indian Wood Circle Maumee, OH 43537

Product Line: Series V-2 Sliding Glass Door 5 x 8 Panel non-impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-03871, prepared, signed and sealed by Luis Roberto Lomas P.E.
- Test report No.: NCTL 110-15153-1 signed and sealed by Robert H Zeiders P.E. National Certified Testing Laboratories, York, PA
 - TAS 202 Uniform Static Air Pressure, ±65.0psf design pressure, 12.0psf water penetration.
- Anchor calculations with comparative analysis, report number 515099-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: Refer to approval drawing.
- Approved configurations: Units with 4 panels maximum in unlimited configurations are approved as long as
 - individual panel area does not exceed 41.59 ft² and frame area does not exceed
 - 254.48 ft² and uses vertical conditions as shown in approval drawing.
- Units must be glazed per ASTM E1300 using safety glazing.
- This product is rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded Aluminum 6063-T6

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-03871.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

No. 6251# *

No. 6251#

No. 6251#

STATE OF

NO. 6251#

STATE OF

NO. 6251#

Luis R. Lomas, P.E. FL No.: 62514 12/19/2022