

*L. Roberto Lomas P.E.*

400 S Palm Ave  
Indialantic, FL 32903  
434-688 0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 515142

**Manufacturer:** Stergis Windows and Doors  
79 Walton Street  
Attleboro, MA 02703

**Product Line:** 1100 Sliding Glass Door – Impact, HVHZ

**Compliance:**

The product listed herein complies with the requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03896, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NCTL 210-4044-02 signed and sealed by Gerard J. Ferrara P.E.  
National Certified Testing Laboratories, Orlando, FL  
TAS 201/TAS203 Large Missile Impact Test, Level D, Wind Zone 4  
Cyclic Pressure loading  $\pm 65.0$ psf design pressure  
TAS 202 Uniform Static Air Pressure,  $\pm 65.0$ psf design pressure, 9.0psf water penetration (standard sill), 9.75 (with sill extender).
3. Report No.: NCTL-210-4044-02A signed by Mark Bennett, Manager of Testing Services.  
National Certified Testing Laboratories, Orlando, FL  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure:  $\pm 65.0$ psf  
Water penetration resistance: 9.75psf (with sill extender)  
9.00psf (standard sill)  
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4  
Cyclic Load Test,  $\pm 65.0$ psf design pressure
4. Anchor calculations, report number 515142-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure:  $\pm 65.0$  psf (with sill extender)
- Unit size: 96" X 96"
- Approved configurations: OX, XO.
- Units must be glazed per ASTM E1300, according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded vinyl.
- Units must installed with sill extender.

**Installation:**

Units must be installed in accordance with manufacture's installation instructions and approval document 08-03896.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

