

*L. Roberto Lomas P.E.*

400 S. Palm Ave.  
Indialantic, FL 32903  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 514798

**Manufacturer:** MI Windows and Doors, LLC  
650 West Market St.  
Gratz, PA 17030

**Product Line:** M-9310 Vertical Mullion

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03678, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report 11398.04-106-12 signed by Michael D. Stremmel P.E.  
Molimo, LLC, York PA  
AAMA 450 Option 1  
Design pressure: +60.15/-55.14psf  
Water penetration resistance: 12.12psf
3. Mullion analysis, report number 514798-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure: Refer to design pressure charts in approval document.
- Single window unit size: Refer to charts in approval document
- Window units attached to mullion must have their own separate approval.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions, up to wind zone 3.
- Design pressure of mulled units shall be controlled by the lesser design pressure of the assembly components; mullion or individual units.
- All windows attached to mullion must be manufactured by MI Windows and Doors, LLC.

**Installation:**

Mullion must be installed in accordance with manufacturer's installation instructions and approval document 08-03678.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

