

Engineering Evaluation Report # MartinGD-081123

Prepared by:

A. Lynn Miller, P.E.
1070 Technology Dr.
N. Venice, FL 34275
(941) 480-1600
Registration Number: #29296

Manufacturer:

Martin Door Manufacturing
2828 South 900 West
Salt Lake City, UT 84119

Product Description:

Non-Impact-resistant, Steel, Insulated Garage Door, FL #42287

Compliance:

The above-mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61 G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

This product has been evaluated and is in compliance with the 2020 & 2023 Florida Building Code, not including the "High Velocity Hurricane Zone" (HVHZ).

Supporting Technical Documentation:

1. Approval document: drawing number GD-FPA-1, signed and sealed by A. Lynn Miller, P.E.
2. Test Report NOK-0052
QAI Laboratories, Nokomis, FL 34275
ANSI/DASMA 108-17 & ASTM E330-14
3. Calculations, signed and sealed by A. Lynn Miller, P.E., dated 8/2/23

Limitations and Conditions of use:

- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and does require impact protection in wind borne debris regions.
- Panel material to be Steel.
- Units must be installed in accordance with approval document, GD-FPA-1.



A. LYNN MILLER, P.E.
P.E.# 58705