

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

# **Product Evaluation Report**

of

Panoramic Doors
Chamberlin Aluminum Folding Door
(Non-HVHZ) (Non-Impact)

for

Florida Product Approval

FL# FL42298

Report No. 8708

### **Current Florida Building Code**

Method: 1 - D (Engineering Evaluation)

**Category:** Exterior Doors

Sub – Category: Swinging Exterior Door Assemblies

**Product:** Chamberlin Aluminum Folding Door

Materials: Aluminum 6063-T6

**Product Dimensions:** See Installation Instructions, PAD009

#### **Prepared for:**


Panoramic Doors 15050 Frye Road Fort Worth, TX 76155

## **Prepared by:**

Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 08/08/2023

Contents:

Evaluation Report Pages 1 – 3





FL#: FL42298
Report #: 8708
Date: 08/08/2023

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Manufacturer: Panoramic Doors

**Product Category:** Exterior Doors

**Product Sub-Category:** Swinging Exterior Door Assemblies

**Compliance Method:** State Product Approval Method (1)(d)

Product Name: Chamberlin Aluminum Folding Door

(Non-HVHZ) (Non-Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for Panoramic

**Doors** based on Method 1d of the State of Florida Product Approval, Department of Business

and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval

process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building

Code.

See Installation Instructions **PAD009**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778)

for specific use parameters.

#### **Limits of Use:**

- 1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
- 2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
- 3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and <u>does require</u> an impact resistant covering.
- 4. Site conditions that deviate from the details of installation instructions **PAD009** require further engineering analysis by a licensed engineer or registered architect.
- 5. See Installation Instructions **PAD009** for size and design pressure limitations.



FL#: FL42298 Report #: 8708 08/08/2023 Date:

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

The manufacturer has demonstrated compliance of manufacture of products **Quality Assurance:** 

in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity

through **Keystone Certifications, Inc.** (FBC Organization # QUA1824)

**Performance Standards:** The product described herein has been evaluated per:

ASTM E283-04(12)

**ASTM E330-14** 

ASTM E547-00(16)

**Referenced Data:** 

1. Product Testing performed by Architectural Testing, Inc. (an Intertek

company) - Plano, TX

(FBC Organization # TST1910)

Report #: P9077.01-801-44, Report Date: 05/23/23

Installation:

Refer to Installation Instructions (PAD009) for anchor spacing and more details of the

installation requirements.

**Design Pressure:** 

Refer to Installation Instructions (PAD009) for design pressures based on size, configuration,

and glass types.





