



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

## Product Evaluation Report

*of*

**Panoramic Doors  
Coastal Storm Door  
(Non-HVHZ) (Non-Impact)**

*for*

**Florida Product Approval**

**FL# FL42307**

**Report No. 8705**

**Current Florida Building Code**


<b>Method:</b>	<b>1 – D (Engineering Evaluation)</b>
<b>Category:</b>	<b>Exterior Doors</b>
<b>Sub – Category:</b>	<b>Swinging Exterior Door Assemblies</b>
<b>Product:</b>	<b>Coastal Storm Door</b>
<b>Materials:</b>	<b>Aluminum 6063-T6</b>
<b>Product Dimensions:</b>	<b>See Installation Instructions, PAD006</b>

**Prepared for:**

**Panoramic Doors  
15050 Frye Road  
Fort Worth, TX 76155**

**Prepared by:**

**Hermes F. Norero, P.E.**  
Florida Professional Engineer # 73778  
Date: 08/14/2023



Contents:

Evaluation Report      Pages 1 – 3

Hermes F. Norero, P.E.  
Florida No. 73778

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

**Manufacturer:** Panoramic Doors

**Product Category:** Exterior Doors

**Product Sub-Category:** Swinging Exterior Door Assemblies

**Compliance Method:** State Product Approval Method (1)(d)

**Product Name:** Coastal Storm Door  
(Non-HVHZ) (Non-Impact)

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Panoramic Doors** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **PAD006**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

**Limits of Use:**

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does require** an impact resistant covering.
4. Site conditions that deviate from the details of installation instructions **PAD006** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **PAD006** for size and design pressure limitations.

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

**Quality Assurance:** The manufacturer has demonstrated compliance of manufacture of products in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Keystone Certifications, Inc.** (FBC Organization # QUA1824)

**Performance Standards:** The product described herein has been tested per:

- TAS 202-94

**Referenced Data:**

1. Product Testing performed by **Architectural Testing, Inc. (an Intertek company) - Plano, TX**  
(FBC Organization # TST1910)  
Report #: Q1572.01-801-18, Report Date: 08/14/23  
Report Signed and Sealed by Tyler Westerling, FL PE No. 72012

**Installation:**

Refer to Installation Instructions (**PAD006**) for anchor spacing and more details of the installation requirements.

**Design Pressure:**

Refer to Installation Instructions (**PAD006**) for design pressures based on size, configuration, and glass types.