

L. Roberto Lomas P.E.

208 7th Ave

Indialantic, FL 32903

434-688-0609

rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 515282

Manufacturer: Eastern Architectural Systems
16341 Domestic Avenue
Ft. Myers, FL 33913

Product Line: Series “279.043” Vinyl Double Hung Window Non-Impact

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03989, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: P9404.02-109-47 signed by Jonathan Dodd
Intertek, Pittsburg, PA
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ± 60.0 psf
Water penetration resistance: 7.52psf (with sill extension 10005131)
9.19psf (with sill extension 10005139)
3. Anchor calculations, report number 515282-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 50.0 psf with sill extension 10005131
 ± 60.0 psf with sill extension 10005139
- Unit size: 52” x 75”
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Extruded PVC.

Installation:

Units must be installed in accordance with manufacturer’s installation instructions and approval document 08-03989.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

