



1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

## Product Evaluation Report

of

**De La Fontaine  
Inswing Single Flush Steel Door  
(HVHZ)(Impact)**

for

**Florida Product Approval**

**FL# FL46851**

**Report No. 9319**

**Current Florida Building Code**

<b>Method:</b>	<b>1 – D (Engineering Evaluation)</b>
<b>Category:</b>	<b>Exterior Doors</b>
<b>Sub – Category:</b>	<b>Swinging Exterior Door Assemblies</b>
<b>Product:</b>	<b>Inswing Single Flush Steel Door</b>
<b>Materials:</b>	<b>18 Ga. Min. Cold Rolled Steel</b>
<b>Product Dimensions:</b>	<b>See Installation Instructions, DLF006</b>

**Prepared for:**

**De La Fontaine  
4115 Brodeur Street  
Sherbrooke, QC J1L1K4**

**Prepared by:**


**Hermes F. Norero**

Florida Professional Engineer # 73778

Date: 6/21/2024

Contents:

Evaluation Report      Pages 1 – 3



Hermes F. Norero, P.E.  
Florida P.E. No. 73778

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

**Manufacturer:** De La Fontaine

**Product Category:** Exterior Doors

**Product Sub-Category:** Swinging Exterior Door Assemblies

**Compliance Method:** State Product Approval Method 1(d)

**Product Name:** Inswing Single Flush Steel Door  
(HVHZ)(Impact)

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **De La Fontaine** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code.

See Installation Instructions **DLF006**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

**Limits of Use:**

1. This product has been evaluated and is in compliance with the Florida Building Code, **including** the “High Velocity Hurricane Zone” (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Florida Building Code and **does not require** an impact resistant covering.
4. Site conditions that deviate from the details of Installation Instructions **DLF006** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **DLF006** for size and design pressure limitations.

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

**Quality Assurance:** The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Intertek Testing Services NA, Inc. - QA Entity**. (FBC Organization #: QUA1673)

**Performance Standards:** The product described herein has been tested per:

- TAS 201-94
- TAS 202-94
- TAS 203-94
- ASTM E283-04(12)
- ASTM E330-14(21)
- ASTM E1886-19
- ASTM E1996-17

**Referenced Data:**

1. Product Testing performed by **QAI Laboratories**  
(FBC Organization # TST1657)  
Report #: MED-1233a, Report Date: 05/23/24  
All reports signed and sealed by Idalmis Ortega, FL P.E. No 76905
2. Quality Assurance  
**Intertek Testing Services NA, Inc. - QA Entity**  
(FBC Organization # QUA1673)
3. Material Certification  
**Miami-Dade County Notice of Acceptance**  
**Kuraray America, Inc.**  
SentryGlas Interlayer

**Installation:** Refer to Installation Instructions (**DLF006**) for qualified installation methods and requirements.

**Design Pressure:** Refer to Installation Instructions (**DLF006**) for design pressures dependent on hardware type, configuration, and size of units.