



1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Product Evaluation Report

of

**Oliveri Millworks
Outswing Wood Double and Single Door
(HVHZ) (Impact)**

for

Florida Product Approval

FL# FL47485

Report No. 9852

Current Florida Building Code

Method: 1 – D (Engineering Evaluation)
Category: Exterior Doors
Sub – Category: Swinging Exterior Door Assemblies
Product: Outswing Wood Double and Single Door
Materials: Mahogany
Product Dimensions: See Installation Instructions, OVM004

Prepared for:

**Oliveri Millworks
3001 Tuxedo Avenue
West Palm Beach, FL 33405**


Prepared by:

Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 4/23/2025

Contents:

Evaluation Report

Pages 1 – 4



1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Manufacturer: Oliveri Millworks

Product Category: Exterior Doors

Product Sub-Category: Swinging Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(d)

Product Name: Outswing Wood Double and Single Door (HVHZ) (Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Oliveri Millworks** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **OVM004**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **including** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does not** require an impact resistant covering.
4. Site conditions that deviate from the details of installation instructions **OVM004** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **OVM004** for size and design pressure limitations.

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Quality Assurance:

The manufacturer has demonstrated compliance of manufacture of products in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **National Accreditation and Management Institute**. (FBC Organization #QUA1789)

Performance Standards:

The product described herein has been evaluated per:

- ASTM E283/E283M-19
- ASTM E330/E330M-14(21)
- ASTM E331/E331M-00(16)
- ASTM E1886-19
- ASTM E1996-20
- TAS 201-94
- TAS 202-94
- TAS 203-94

Referenced Data:

1. Product Testing performed by **Blackwater Technical Services Inc.**
(FBC Organization #TST10394)
Report #: BT-MWA-24-004 Report Date: 04/23/2025
TAS reports signed and sealed by Michael D. Caldwell, P.E. No. 49979
2. Quality Assurance
National Accreditation and Management Institute.
(FBC Organization #QUA1789)
3. Material Certification
Miami-Dade County Notice of Acceptance
Kuraray Co., Ltd.
SentryGlas Interlayer

Installation:

Refer to Installation Instructions (**OVM004**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (**OVM004**) for design pressures based on size, configuration, and glass types.

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. Oliveri Millworks has tested their products to the following test standard edition(s):

- 1) ASTM E1886-23
- 2) ASTM E1996-23

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) ASTM E1886-19
- 2) ASTM E1996-20

After review of the above mentioned referenced standards and editions, it has been found that the results and tests carried out meet the requirements for compliance. All referenced standards have been found to be equivalent.