

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Product Evaluation Report

of
Oliveri Millworks
Direct-Set Fixed Window
(HVHZ) (Impact)

for
Florida Product Approval

FL# FL47486

Report No. 9850

Current Florida Building Code

Method: 1 − D (Engineering Evaluation)

Category: Windows

Sub – Category: Fixed

Product: Direct-Set Fixed Window

Materials: Mahogany

Product Dimensions: See Installation Instructions, OVM002

Prepared for:


Oliveri Millworks 3001 Tuxedo Avenue West Palm Beach, FL 33405

Prepared by:

Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 4/23/2025

Contents:

Evaluation Report Pages 1 – 4





FL#: FL47486 Date: 4/23/2025 Report No: 9850

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Manufacturer: Oliveri Millworks

Product Category: Windows

Product Sub-Category: Fixed

Compliance Method: State Product Approval Method (1)(d)

Product Name: Direct-Set Fixed Window

(HVHZ) (Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for Oliveri

Millworks based on Method 1d of the State of Florida Product Approval, Department of

Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **OVM002**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

- 1. This product has been evaluated and is in compliance with the current Florida Building Code, <u>including</u> the "High Velocity Hurricane Zone" (HVHZ).
- 2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
- 3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and <u>does not</u> require an impact resistant covering.
- 4. Site conditions that deviate from the details of installation instructions **OVM002** require further engineering analysis by a licensed engineer or registered architect.
- 5. See Installation Instructions **OVM002** for size and design pressure limitations.



FL#: FL47486 Date: 4/23/2025 Report No: 9850

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

The manufacturer has demonstrated compliance of manufacture of products **Quality Assurance:**

> in accordance with the current Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance

entity through National Accreditation and Management Institute.

(FBC Organization #QUA1789)

Performance Standards: The product described herein has been evaluated per:

ASTM E283/E283M-19

ASTM E330/E330M-14(21)

ASTM E331/E331M-00(16)

ASTM E1886-19

ASTM E1996-20

TAS 201-94

TAS 202-94

TAS 203-94

Referenced Data:

1. Product Testing performed by Blackwater Technical Services Inc.

(FBC Organization #TST10394)

Report #: Report Date: BT-MWA-24-005 04/16/2025

TAS reports signed and sealed by Michael Caldwell, P.E. No. 49979

2. Quality Assurance

National Accreditation and Management Institute.

(FBC Organization #QUA1789)

Installation:

Refer to Installation Instructions (OVM002) for anchor spacing and more details of the installation requirements.

Design Pressure:

Refer to Installation Instructions (OVM002) for design pressures based on size, configuration, and glass types.



954.744.4738

954.399.8478







FL#: FL47486 Date: 4/23/2025 Report No: 9850

1900 NE MIAMI CT. SUITE 2-15, MIAMI, FL 33132

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. Oliveri Millworks has tested their products to the following test standard edition(s):

- 1) ASTM E1886-23
- 2) ASTM E1996-23

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) ASTM E1886-19
- 2) ASTM E1996-20

After review of the above mentioned referenced standards and editions, it has been found that the results and tests carried out meet the requirements for compliance. All referenced standards have been found to be equivalent.

