

## PRODUCT APPROVAL EVALUATION REPORT

<u>Product Manufacturer:</u> <b>UNI-K Fenestration LLC.</b> 3201 NE 183 Street, Unit 3008 Aventura, Florida 33160	<u>Product Name/Model &amp; Description:</u> Horizontal rolling window – large and small missile impact
--	--

**Scope:** This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Evaluation of this product shall be required following applicable Code modifications or revisions.


**Code:** 8<sup>th</sup> Edition Florida Building Code (2023), inclusive of all Supplements effective as of this report date.

**Compliance Method:** 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer


**Product Description:** Product Approval Drawing #AD25-56 and #AD25-59, prepared by MCY Engineering, signed and sealed by Yiping Wang, P.E., is an integral part of this Evaluation Report.

### Limitations & Conditions of Use:

- This product has been evaluated for use **inside and outside of the HVHZ** (High-Velocity Hurricane Zone)
- Impact Resistance: **large and small missile Impact**
- Refer to Product Approval Drawing noted above for:
  - Maximum allowable wind loads at the related maximum allowable size(s).
  - Other load limitations are applicable to the product, if any.
  - Overall dimensions and material/grade of main product components, accessories, etc.
  - Illustrated diagrams of the attachment of the product to the structure
  - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.



January 16th, 2026



**Test Reports:**

**Mandatory Tests (Tested in accordance with Florida Building Code Tests Protocols)**

Test Lab	Report Number	Test Report Date	Test Standard & Description
QAI laboratories 8148 NW 74 Avenue Medley, FL33166 Ph:305.885.3328	<i>MED 3598a</i> <i>Signed and sealed by</i> <i>Idalmis Ortega</i>	12/11/2025	TAS 201 (large and small missile impact) TAS 202 (uniform static test) TAS 203 (cyclic load test) ASTM E283 (air and water infiltration) ASTM E331 (water resistance test) ASTM F588 (force entry)

**Engineering Analysis:** The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- No rational analysis has been performed.
- Anchor calculations are based on manufacturer’s published anchor capacity, anchor Notice of Acceptance by Miami Dade County.



January 16th, 2026